

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No. 07

Dated: 25/02/26

It is certified that an inspection team headed by Dr. SAURABH SINGH PARJHAR
(Name of Officers with designation) from MEDICAL OFFICER CHC BURHAR

PHED inspected the Seven Ocean Public School, Ward no. 15 Nagar Parishad Bakho, Jhagarha, Tehsil
Burhar, Dist.- Shahdol MP on 25/02/26 and on the basis of Water Test Report (Attached)
bearing no. 135 dated 24/02/2026 of

PUBLIC HEALTH ENGINEERING DEPARTMENT (PHED Lab)

certified that the Seven Ocean Public School, Ward no. 15 Nagar Parishad Bakho, Jhagarha, Tehsil Burhar,
Dist.- Shahdol MP has safe drinking water facilities for the students and members of staff of the institution.
School is also maintains the hygienic sanitation condition in the school building & the campus as per norms
prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 26/02/27

Signature with seal

Name

Designation

Name & address of the office/Department: - CHC BURHAR

To,
Seven Ocean Public School, Ward no. 15 Nagar Parishad Bakho,
Jhagarha, Tehsil Burhar, Dist.- Shahdol MP
(Name and address of the institution)

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies



**SUB DIVISION WATER TESTING LABORATORY
PUBLIC HEALTH ENGINEERING DEPTT. BURHAR, DISTT - SHAHDOL (M.P.)**

District Shahdol

Block- Burhar

	Gram p.	Village
1		
2		
3		
4		

SA.No & Details Source & Location

Particular of Sample
Date of collection **23/02/26**
Date of Analysis **23/02/26**

1 Seven Ocean Public School

Table -2.2 BIS Standard : Is-10500-1991

S.No.	Characteristics	Unit	Receipt Destrable limit	Permissible limit in the absence of alternative	Result	Sample No.
					01	

PHYSICAL TEST

1	Turbidity	N.T.U.	1	5	3.2	
2	Colour	Hazen units	1	5	0	
3	Taste	-	Agreeable	Not Agreeable	Agreeable	
4	Odour	-	Unobjection able	objection able	Un objection able	

CHEMICAL TEST

5	PH	PH Scale	6.5 TO 8.5	No relaxation	7.1	
6	Conductivity	Micro Mhos/cm-			72	
7	Total Alkalinity	mg/l	200	600	60	
8	Chlorides(As Ci)	mg/l	250	1000	18	
9	Nitrates (As No 3)	mg/l	45	45	0	
10	Total Hardness(As Caco3)	mg/l	200	600	88	
11	Total Dissolved Solids	mg/l	500	2000	56	
12	Iron (As Fee)	mg/l	0.3	1.0	0.2	
13	Fluorides (As F)	mg/l	1.0	1.5	0.1	
14	Sulphatest (As so4)	mg/l	200	400	24	
15	Calcium	mg/l	75.0	200.0	-	
16	Mangneccium	mg/l	30.0	100.0	-	

BACTROLOGICAL TEST

17	Coliform Organisms at 37c	M.P.N/100 ml.			Nil	
----	---------------------------	---------------	--	--	-----	--

TESTED BY- Amrita Singh Marko

(Handwritten signature)
Secretary

(Handwritten signature)
PRINCIPAL

(Handwritten signature)
Chemist
Name & Signature
of Lab Incharge